



514 Market Street, Wilmington NC 28401
phone 910.762.2621 fax 910.762.8506
www.bmharch.com

March 1, 2019

ADDENDUM #3

Renovations to:
M.C.S. Noble Middle School
6520 Market Street
Wilmington NC 28405

Project ID: 900-9008

This addendum forms a part of the contract documents and modifies the original drawings and project manual dated February 2019. The enclosed additions, deletions, corrections, and changes shall be as binding as if incorporated in the original documents. All General Conditions, Special Conditions, etc. as originally specified shall apply to these items. Acknowledgement of receipt of this addendum will be required as part of the contract agreement.

- Item 1** **Drawings, A3.01 Finish Schedules and Wall Types**
Clarification. Dal-Tile confirmed TL-2 Colorbody Procelain, Mosaics 12” sheets is in production and available.

- Item 2** **Drawings, ID-101A Interior Design Floor Pattern Plan Area A & Enlarged Lockers & Toilets**
Custom VCT Noble Logo called out in Lobby 100 is included as **Attachment #1.**

- Item 3** **Drawings, E0.2 Electrical Notes and Lighting Fixture Schedule**
Revise Lighting Fixture Schedule as follows:

Delete Remark 8 from Fixtures A2, A3, B2.


Fixtures A2, A3 and B2 have REMARKS referencing note 8 for built-in sensors with daylight / motion / communication /zone prog to be provided, this option is not required for these fixtures.

SUBSTITUTION REQUESTS STATUS

All product substitutions listed as “Allowed” shall comply with all requirements of the drawings and specifications. It is the responsibility of the General Contractor to ensure that substitute products installed will function properly with Base Bid and Alternate work shown and specified in the construction documents. The General Contractor shall bear the cost of any modifications, material changes, and additional testing necessary to incorporate substitute products should they be required.

Spec Section	Item	Manufacturer	Response
10 21 13	Toilet Compartments	Scranton Products	Approved ADDENDUM #3

Bowman Murray Hemingway Architects, PC

A handwritten signature in black ink, appearing to read "John D. Murray". The signature is fluid and cursive, with a large initial "J" and "M".

John D. Murray AIA