

# NOBLE MIDDLE SCHOOL RENOVATIONS

GENERAL CONTRACTOR ISSUED RESPONSES TO RFIs

ISSUE DATE: MARCH 1, 2019

BID DATE: MARCH 5, 2019



MONTEITH

4. Do you have the CIVIL CAD file for this project

**Included in Addendum #3 on iSqft.**

27. The ID-101B has Corridor N receiving VCT, but on A3.01 Finish Schedule has Corridor N only receiving Rubber Base. Please clarify.

**Please follow ID-101B.**

31. Is food service supplying and installing the new cooler and mechanical just does the refrigerant lines and roof condenser?

**Mechanical contractor is responsible for the refrigerant lines and roof condenser. The food service equipment will be supplied and installed by others.**

32. Para 2.1.C.2. calls for "retractable goal swinging support structure (forward folding) however 2.a.2) calls for Draper TB-25R which is a "rear fold" unit. Which type of basketball backstops are required?

**Please bid per specified product.**

**WE.  
BUILD.  
RELATIONSHIPS.**

**WILMINGTON** 208 PRINCESS ST. WILMINGTON, NC 28401

**CHARLESTON** 460 KING ST. SUITE 200 CHARLESTON, SC 29403

**MYRTLE BEACH** 1200 48TH AVE. N. SUITE 102 MYRTLE BEACH, SC 29577

**RALEIGH** 610 HILLSBOROUGH ST. SUITE 103 RALEIGH, NC 27603

NC GC LICENSE NO. 43319 SC GC LICENSE NO. G99696 VA GC LICENSE NO. 2705168546