



hostetlerarchitecture
ARCHITECTURE ■ PLANNING
 3967 MARKET STREET
 WILMINGTON, NC 28403
 PHONE: 910.612.1119
 www.hostetlerarchitecture.com

CONSULTANTS
 10755

 McDOWELL CONSULTING
 ENGINEERS, INC.
 P.O. BOX 367
 HAMPSTEAD, NC 28443
 TEL: (910) 270-3747 FAX: 270-3779
 NC LICENSE NO. C-2546



RENOVATIONS TO
GRACE BAPTIST CHURCH
 WILMINGTON
 NORTH CAROLINA

CONSTRUCTION DOCUMENTS : 2.8.19

REVISIONS		
MARK	DATE	DESCRIPTION
△		
△		
△		
△		

DRAWN BY: RSG PROJ. MGR: GLM

SHEET CONTENT

SANCTUARY BUILDING (BASE BID)
 SECOND FLOOR PLAN
 ELECTRICAL - LIGHTING

JOB NO. 18013	SHEET E204
-------------------------	-----------------------------

NOTE: PLAN SHOWS RESTORING LIGHTING CONTROLS TO PRE-DAMAGED CONDITIONS. UPGRADE TO LATEST CODE NOT IN SCOPE OF WORK.

NOTE: DIMMERS SHALL BE SLIDE TYPE WITH PRE-SET, COMPATIBLE WITH FIXTURES/LAMPS TO BE CONTROLLED. SIZE FOR MINIMUM 125% OF LOAD CONTROLLED. PROVIDE 0-10V DIMMING CONTROL WIRING WHERE REQUIRED.

SCOPE OF WORK:
 AREA SUSTAINED WATER DAMAGE FROM HURRICANE. PROVIDE NEW LIGHT FIXTURES. REPLACE EXISTING SWITCHES AS SHOWN. RE-USE EXISTING BRANCH CIRCUITS. TEST CIRCUITS FOR INTEGRITY & CONTINUITY.

NOTE: SHADED FIXTURES ARE EXISTING AND REMAINED IN PLACE AFTER STORM DEMO.

SANCTUARY BUILDING (BASE BID)
 SECOND FLOOR PLAN - LIGHTING
 SCALE: 1/8"=1'-0"

lmed 4/18/2014