



NOTE: DIMMERS SHALL BE SLIDE TYPE WITH PRE-SET, COMPATIBLE WITH FIXTURES/LAMPS TO BE CONTROLLED. SIZE FOR MINIMUM 125% OF LOAD CONTROLLED. PROVIDE 0-10V DIMMING CONTROL WIRING WHERE REQUIRED.

NOTE: SHADED FIXTURES ARE EXISTING AND REMAINED IN PLACE AFTER STORM DEMO.

- REFERENCE NOTES:
- ① CONNECT LED COVE LIGHTING. COORD W/GC AND ARCH PLANS. PHANTOM DYNAMICS ACCLAIM FLX777 FLEX CHANNEL AND FLEX COVE LIGHTING TAPE.
 - ② CONNECT TO EXISTING LIGHTING BRANCH CIRCUIT. RE-USE EXISTING SWITCHES.



hostetlerarchitecture
ARCHITECTURE ■ PLANNING
 3967 MARKET STREET
 WILMINGTON, NC 28403
 PHONE: 910.612.1119
 www.hostetlerarchitecture.com

CONSULTANTS
 10755

 McDOWELL CONSULTING ENGINEERS, INC.
 P.O. BOX 367
 HAMPSTEAD, NC 28443
 TEL: (910) 270-3747 FAX: 270-3779
 NC LICENSE NO. C-2546



RENOVATIONS TO

GRACE BAPTIST CHURCH

WILMINGTON
 NORTH CAROLINA

CONSTRUCTION DOCUMENTS : 2.8.19

REVISIONS		
MARK	DATE	DESCRIPTION
△		
△		
△		
△		

DRAWN BY: RSG | PROJ. MGR: GLM

SHEET CONTENT

SANCTUARY BUILDING (ALT BID) SECOND FLOOR PLAN ELECTRICAL - LIGHTING	
JOB NO. 18013	SHEET E207

SANCTUARY BUILDING (ALT BID)
 SECOND FLOOR PLAN - LIGHTING
 SCALE: 1/8" = 1'-0"

imcd 4/18/2014