

**NAVFAC
SPECIFICATION**

**6878897
B-4225 Replace HVAC
System and Controls**

**FRC-East
MCAS Cherry Point, NC
AMENDMENT #0001**

IMPORTANT

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.

If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1	OF PAGES 3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 08/15/2019	4. REQUISITION/PURCHASE REQ. NO. 6878897	5. PROJECT NO. (If applicable)		
6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533		Code N40085	7. ADMINISTERED BY (If other than item 6.)		Code
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION B4225 Replace HVAC System and Controls	
			<input type="checkbox"/>	9B. DATED (SEE ITEM 11)	
			<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
			<input type="checkbox"/>	10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

6878897 – B-4225 Replace HVAC System and Controls, FRC-East, Marine Corps Air Station Cherry Point, NC

This amendment is being issued to respond to pre-award RFIs, provide a new specification sections, and updated drawings.

The deadline to submit pre-award RFIs has passed.

The proposal due date is extended to 22 August 2019 by 1200.

See Attached.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

PROJECT TABLE OF CONTENTS

Delete Project Table of Contents in its entirety and replace with the revised Project Table of Contents, dated 8/6/19, as shown in the footer, which is attached to and made part of this Amendment.

DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS

SECTION 00 01 15, LIST OF DRAWINGS,

Delete Specification Section in its entirety and replace with the revised Specification Section 00 01 15, LIST OF DRAWINGS, dated 8/6/19, as shown in the footer, which is attached to and made part of this Amendment.

1.2 CONTRACT DRAWINGS

The following drawings are revised as of 8/6/19:

NAVFAC DWG NO.	TITLE
12782402	TITLE SHEET
12782429	MECHANICAL DEMOLITION PARTIAL ROOF PLAN - AREA A
12782430	MECHANICAL DEMOLITION PARTIAL ROOF PLAN - AREA B
12782431	MECHANICAL DEMOLITION PARTIAL ROOF PLAN - AREA C
12782432	MECHANICAL DEMOLITION PARTIAL ROOF PLAN - AREA D
12782435	MECHANICAL DUCTWORK PARTIAL FLOOR PLAN - AREA B
12782439	MECHANICAL PIPING PARTIAL FLOOR PLANS - AREA B
12782440	MECHANICAL PIPING PARTIAL FLOOR PLAN - AREA C
12782441	MECHANICAL PIPING PARTIAL FLOOR PLAN - AREA D
12782442	MECHANICAL PARTIAL ROOF PLAN - AREA A
12782443	MECHANICAL PARTIAL ROOF PLAN - AREA B
12782444	MECHANICAL PARTIAL ROOF PLAN - AREA C
12782445	MECHANICAL PARTIAL ROOF PLAN - AREA D
12782447	MECHANICAL DETAILS
12782448	MECHANICAL DETAILS
12782449A	MECHANICAL DETAILS
12782450	MECHANICAL SCHEDULES
12782451	MECHANICAL SCHEDULES
12782453	MECHANICAL CONTROLS
12782455	MECHANICAL CONTROLS
12782456	MECHANICAL CONTROLS

These drawings were revised as of 8/6/19. These revised drawings accompany and are made part of this Amendment.

DIVISION 01 – GENERAL REQUIREMENTS

SECTION 01 14 00, WORK RESTRICTIONS

Delete Specification Section in its entirety and replace with the revised Specification Section 01 14 00, WORK RESTRICTIONS, dated 8/6/19, as shown in the footer, which is attached to and made part of this Amendment.

DIVISION 23 – HEATING, VENTILATING, AND AIR CONDITIONING

SECTION 23 54 19, BUILDING HEATING SYSTEMS, WARM AIR

Delete Specification Section in its entirety and replace with the revised Specification Section 23 54 19, BUILDING HEATING SYSTEMS, WARM AIR, dated 8/6/19, as shown in the footer, which is attached to and made part of this Amendment.

RFI Responses:

1. Who is responsible for providing the wind rated roof curbs, curb adapters, supports, etc
Response: Submit Proposals in accordance with RFP, Specifications, Drawings, and all Amendments.
2. Roof curb adapter note on M-302, M-303 & M-304 states the adapter curb must be wind rated w/ P.E. calcs. Do the RTU's that are being provided with new roof curbs have the same requirement?
*Response: Refer to revised Sheets M-302, M-303, and M-304.
Submit Proposals in accordance with RFP, Specifications, Drawings, and all Amendments.*
3. For the RTU's that require adapter curbs, what is the make/models and/or dimensions of the existing equipment?
*Response: Refer to revised Sheets MD301, MD302, MD303, and MD304.
Submit Proposals in accordance with RFP, Specifications, Drawings, and all Amendments.*
4. There are electric duct heaters shown on M-102 but I do not see a schedule or any info on these. Are these existing to remain or new? If new, will any information be provided?
*Response: Refer to Revised Sheet M-102 Duct heaters are indicated as ETR (existing to remain).
Submit Proposals in accordance with RFP, Specifications, Drawings, and all Amendments.*
5. Who is responsible for providing the Variable Frequency Drives on the RTU's & AHU's?
*Response: Refer to "Motor Coordination" note under "General Electrical Notes" on sheet E-001.
Submit Proposals in accordance with RFP, Specifications, Drawings, and all Amendments.*
6. Are the Variable Frequency Drives on the RTU's & AHU's unit mounted or remote mounted?
Response: Submit Proposals in accordance with RFP, Specifications, Drawings, and all Amendments.