

## **RFB 25-0231 STAR Reno Addendum 2 – Questions & Answers**

1. Confirm that wood doors should be field stained and not factory finished.  
Wood doors to be factory finished, Architect to select stain from manufacturer's range of colors.
2. Are HM frames to be welded or knock down? Are they to be factory or field finished? Frames to be welded, factory finished with prime coat and field finished.
3. There seems to be casework in Patient Rooms 115-125 however there are no details for this condition. Please confirm. Shelves shown in patient rooms 11-125 will be part of the furniture package provided by owner.